

Stainless Steel

Saddles

8403, 8405, 8407 series

8413, 8415, 8417 series



Cambridge Brass

140 Orion Place, PO Box 249

Cambridge, Ontario N1R 5V1

800 265 6638 Canada

800 724 3906 US

519-621-5520

www.cambridgebrass.com

To whom it may concern:

This letter is to confirm that Cambridge Brass Teck Stainless Steel Saddles are for use on the following pipe materials:

- C900, C905, C906, C909 pipe materials (DI dimension)
- Ductile Iron
- IPS PVC
- IPS HDPE (use Belleville Washer Kit 46-2 when used on HDPE pipe)

This is not an exhaustive list, but represents many of the common pipe materials encountered in Municipal distribution of potable water.

Teck Stainless Steel Saddles are NOT for use with Concrete Pressure Pipe (CPP).

Should you have any questions or concerns, please contact your Sales representative, or contact Customer Service at the numbers above.

Don Stark, P.Eng
Director of Technical Services
Cambridge Brass