



Certificate of Compliance

Certificate: 1670410 **Master Contract:** 160622 (086116_0_000)
Project: 70184408 **Date Issued:** 2018-06-21
Issued to: Cambridge Brass Inc.
140 Orion Pl
Cambridge, Ontario N1R 5V1
CANADA
Attention: Brian Chapman

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Drinking Water
NSF/ANSI 61 & 372

Issued by: Brook Hatton
Brook Hatton

PRODUCTS

CLASS - C686108 - MECHANICAL DEVICES - NSF/ANSI 61 SECTION 8-Certified to NSF/ANSI 61
CLASS - C685301 - LOW LEAD CONTENT CERTIFICATION PROGRAM-PLUMBING PRODUCTS--

Non-Lead Brass Plumbing Components: AAANL-B-C-D-E (Cold 23°C)

Notes:

AAA indicates Series #: 32, 81, 83, 98, 105, 110, 111, 117, 118, 119, 120, 150, 151, 152, 155, 171, 172, 173, 202, 203, 204, 205, 210, 212, 213, 214, 224, 230, 234, 240, 244, 252, 253, 262, 263, 272, 273, 274, 281, 282, 283, 290, 292, 293, 301, 302, 305, 306, 307, 311, 321, 351, 361, 405, 406, 412, 416, 417, 421, 423, 424, 430, 431, 432, 440, 500, 502, 510, 520, 590, 8413, 8415, 8417.

NL indicates non-lead brass

B/D indicate Inlet/Outlet Connection Type: A, B, C, CE, CK, CS, D, F, FM, GJ, H, HE, HI, I, ID, IP, J, K, KE, M, MF, MY, N, NY, O, P, PE, PF, PJ, R, S, SR, T, U, W, XS

C/E indicate Inlet/Outlet size: 1 to 7 (1/2", 5/8", 3/4", 1", 1 1/4", 1 1/2", 2")

Plumbing Components (other materials): AAA-B-C-D-E** (Cold 23°C)



Certificate: 1670410
Project: 70184408

Master Contract: 160622
Date Issued: 2018-06-21

Notes:

AAA indicates Series #: 41, 44, 81, 84, 85, 86, 87, 88, 89, 90, 422, 425, 435, 800, 810, 811, 812, 822, 825, 830, 835, 1625, 1635, 8403, 8405, 8407.

B/D indicate Inlet/Outlet Connection Type: A, B, C, CE, CK, CS, D, F, FM, GJ, H, HE, HI, I, ID, IP, J, K, KE, M, MF, MY, N, NY, O, P, PE, PF, PJ, R, S, SR, T, U, W, XS

C/E indicate Inlet/Outlet size: 1 to 7 (½", 5/8", ¾", 1", 1 ¼", 1 ½", 2")

Note: Products shall be installed in Accordance with the Local Code of the Authority having Jurisdiction.

APPLICABLE REQUIREMENTS

NSF/ANSI 61-2016 - Drinking Water System Components - Health Effects
NSF/ANSI 372-2016 - Drinking Water System Components – Lead Content

Note: Products certified to NSF/ANSI 372 conform to the requirements for "lead free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by Section 1417 of the US Safe Drinking Water Act.

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

All markings required by CSA must be permanent and legible. Devices or components shall be labeled in a manner to ensure that all markings are visible after installation. Where it is not practical to place the markings directly on the device, component or material, the markings shall be located on the container or packaging and/or literature accompanying the device, component or material. The content consists of:

- manufacturer's identification;
- CSA Mark with "C", "US" indicator;
- qualifiers "Drinking Water" and "NSF/ANSI 61" below the CSA Mark;
- Qualifiers "NSF/ANSI 372" or "LLC" or "LOW LEAD CONTENT" below or adjacent the CSA Mark
- product identification (if applicable).